

EC type examination certificate**EG-Baumusterprüfbescheinigung****CE-0085CL0214**Product Identification No.
Produkt-Identnummer**Field of Application**
*Anwendungsbereich*EC Gas Appliances Directive (2009/142/EC)
EG-Gasgeräterichtlinie (2009/142/EG)**Distributor**
*Vertreiber*BAXI S.p.A.
Via Trozzetti, 20, I-36061 Bassano del Grappa (VI)**Product Category**
Produktart

Boilers with flue systems: Condensing combi water heater (3204)

Product Description
Produktbezeichnung

Wall hanging condensing combi water heater with full automatic burner control, gas/combustion-air ratio control and secondary heat exchanger

Model
Modell

BOYLER CONDENS...; PULSAR CONDENS...

Countries of Destination
Bestimmungsländer

AL, AT, BE, BG, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IT, LT, LU, LV, MK, NL, NO, PL, PT, RO, SE, SI, SK, TR

Test Reports
Prüfberichte

supplement test: 17/190/3204/033 from 03.08.2017 (EBI)

Test Basis
*Prüfgrundlagen*2009/142/EG (30.11.2009)
DIN EN 15502-1 (01.10.2015)
DIN EN 15502-2-1 (01.01.2013)**File Number**
Aktenzeichen

17-0579-GEA

23.10.2017 Rie G-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of gas appliances under EC Directive

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Gasgeräten gemäß EG-Richtlinie 2009/142/EG.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Elektrical Data
Elektrische Daten

230 V AC, 50 Hz, IPX5D

Appliance Categories <i>Gerätekatégorien</i>	Supply Pressures <i>Versorgungsdrücke</i>	Countries of Destination <i>Bestimmungsländer</i>	Remarks <i>Bemerkungen</i>
I2E(S)	20/25 mbar	BE	
I2H	20 mbar	DK	
I2N	20/25 mbar	BE	
I3P	37 mbar	BE	
II2E LwLs3P	20,20,13, 37 mbar	PL	
II2E3P	20, 37 mbar	LU	
II2ELL3P	20, 50 mbar	DE	
II2Esi3P	20/25, 37 mbar	FR	
II2H3P	20, 30 mbar	AT, EE, FI, LT, LV, NO, RO, SE, SI	
II2H3P	20, 37 mbar	CZ, ES, GB, GR, HR, IE, IT, PT, SK, TR	
II2H3P	20, 50 mbar	AT	
II2HM3P	20, 37 mbar	IT	
II2HS3P	25, 37 mbar	HU	
II2L3P	25, 37 mbar	NL	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
BOYLER CONDENS 16	nominal heat output: 2,2...12,0 kW nominal heat input (Hi): 2,3...12,4 (drinking water: ...16,5) kW	
BOYLER CONDENS 24: BOYLER CONDENS+ 24; PULSAR CONDENS 24	nominal heat output: 3,4...20,0 kW nominal heat input (Hi): 3,5...20,6 (drinking water: ...24,7) kW	
PULSAR CONDENS 1.24	nominal heat output: 3,4...24,0 kW nominal heat input (Hi): 3,5...24,7 kW	
BOYLER CONDENS 33: BOYLER CONDENS+ 33	nominal heat output: 4,7...28,0 kW nominal heat input (Hi): 4,8...28,9 (drinking water: ...34,0) kW	

Hints of Utilization /Remarks
Verwendungshinweise / Bemerkungen

flue types B23, C13, C33, C43, C53, C63, C83, C93, C13x, C33x, C43x, C53x, C63x, C83x, C93x: according to "installation manual BOYLER CONDENS, PULSAR CONDENS..."

Additionally tested appliance categories, supply pressures and countries of destination:

CY: II2H3P (20, 30 mbar)

AL, BG, MK: II2H3P (20, 37 mbar)

In Albania and in Macedonia the CE-marking will be accepted as conformity approval if the Gas Appliance Directive (2009/142/EC) is transferred into national law by Albania respectively Macedonia.



EC type examination certificate

EG-Baumusterprüfbescheinigung

CE-0085CL0214Product Identification No.
Produkt-Identnummer

Field of Application <i>Anwendungsbereich</i>	EC Efficiency Directive (92/42/EEC) <i>EG-Wirkungsgradrichtlinie (92/42/EWG)</i>
Distributor <i>Vertreiber</i>	BAXI S.p.A. Via Trozzetti, 20, I-36061 Bassano del Grappa (VI)
Product Category <i>Produktart</i>	Boilers with flue systems: Condensing combi water heater (3204)
Product Description <i>Produktbezeichnung</i>	Wall hanging condensing combi water heater with full automatic burner control, gas/combustion-air ratio control and secondary heat exchanger
Model <i>Modell</i>	BOYLER CONDENS...; PULSAR CONDENS...
Type of Boiler <i>Heizkesseltyp</i>	condensing boiler
Test Reports <i>Prüfberichte</i>	supplement test: 17/190/3204/033 from 03.08.2017 (EBI)
Test Basis <i>Prüfgrundlagen</i>	EU/92/42 (21.05.1992)
File Number <i>Aktenzeichen</i>	17-0579-GWA

23.10.2017 Rie G-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to DIN EN ISO/IEC 17065:2013 and notified by the government of the Federal Republic of Germany for certification of heating boilers under EC Directive 92/42/EC.

DVGW CERT GmbH ist von der DAkkS nach DIN EN ISO/IEC 17065:2013 akkreditierte und von der Deutschen Bundesregierung benannte Stelle für die Zertifizierung von Heizkesseln nach der Richtlinie 92/42/EWG.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-04DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Energy Labelling <i>Energieeffizienzkennzeichnung</i>
BOYLER CONDENS 16	nominal heat output: 2,2...12,0 kW nominal heat input (Hi): 2,3...12,4 (drinking water: ...16,5) kW	
BOYLER CONDENS 24: BOYLER CONDENS+ 24; PULSAR CONDENS 24	nominal heat output: 3,4...20,0 kW nominal heat input (Hi): 3,5...20,6 (drinking water: ...24,7) kW	
PULSAR CONDENS 1.24	nominal heat output: 3,4...24,0 kW nominal heat input (Hi): 3,5...24,7 kW	
BOYLER CONDENS 33: BOYLER CONDENS+ 33	nominal heat output: 4,7...28,0 kW nominal heat input (Hi): 4,8...28,9 (drinking water: ...34,0) kW	