

A04



A01 **HUS LTD**
1 Industrialna Str.
3600 Lom, Bulgaria

A02 Inspection certificate EN 10204 / 3.1

A05 **HUS LTD.**

B01 Cold formed welded structural hollow sections of non-alloy and fine grain steels according EN 10219-2:2006

A08	Order №
A06	Customer SZATMARI KFT
A07	Invoice № 3130019827

B02	EN 10219-1 S235JRH	B10	length 6000 mm.
B09	CFRHS		option 1.1 ; 1.4
B09	CFCHS		option 1.1 ; 1.4

B07		B08	8 370 m.
-----	--	-----	----------

B12 B13



B09	CFCHS 42,4x2	B10		B08	546 m.	B13		B06	0001519222989	B07	883676
B09	CFRHS 25x25x2	B10		B08	1014 m.	B13		B06	0001652818989	B07	49230-3
B09	CFRHS 25x25x2	B10		B08	1014 m.	B13		B06	0001652815989	B07	49230-3
B09	CFRHS 25x25x2	B10		B08	1014 m.	B13		B06	0001652107989	B07	413762-9
B09	CFRHS 25x25x2	B10		B08	1014 m.	B13		B06	0001652100989	B07	413762-9
B09	CFRHS 60x60x2	B10		B08	384 m.	B13		B06	0001659958989	B07	3595758
B09	CFRHS 40x30x3	B10		B08	576 m.	B13		B06	0001626566989	B07	1104878
B09	CFRHS 60x40x3	B10		B08	420 m.	B13		B06	0001645166989	B07	910452
B09	CFRHS 60x40x3	B10		B08	420 m.	B13		B06	1000042503989	B07	910452
B09	CFRHS 60x40x3	B10		B08	420 m.	B13		B06	0001616714989	B07	907037
B09	CFRHS 60x40x3	B10		B08	420 m.	B13		B06	0001645179989	B07	90887
B09	CFRHS 60x40x3	B10		B08	420 m.	B13		B06	2000000881989	B07	90887
B09	CFRHS 60x40x3	B10		B08	420 m.	B13		B06	0001616706989	B07	910599
B09	CFRHS 120x60x3	B10		B08	144 m.	B13		B06	0001615404989	B07	43552-8
B09	CFRHS 120x60x3	B10		B08	144 m.	B13		B06	0001615419989	B07	43729-8

[illegible]

B07 Mechanical properties										
Heat №	C00	C03	C11	C12	C13	C14	C42	C50	C70	C71
	Test №		ReH MPa	Rm MPa	A %	ReH/Rm	Impact test	Certificate №		
Y910116	883676		275	408	26		not done	397983		
511227	49230-3		270	390	30		not done	519051		
511227	49230-3		270	390	30		not done	519051		
111646	413762-9		275	389	28		not done	532153		
111646	413762-9		275	389	28		not done	532153		
132348B01	3595758		280	395	32		not done	8494		
018834B02	1104878		294	419	30		not done	7839		
Y911602	910452		285	395	32		not done	403866		
Y911602	910452		285	395	32		not done	403866		
Y924203	907037		270	395	34		not done	403753		
Y911507	90887		299	390	33		not done	403608		
Y911507	90887		299	390	33		not done	403608		
Y924397	910599		290	395	34		not done	404056		
111588	43552-8		271	373	38		not done	621351		
521360	43729-8		274	385	33		not done	623120		

D02 Non-destructive testing - passed.

Z02 Z03 Director Branch Lom
N.Dechev
Date 17.07.2021
Seal HUS LTD.
www.husltd.com



A05 TT

D01 The test has been performed on the provided products and the results are satisfactory.

Z01 The producer declares that the product is according to the customer's order.

Z05 Without any post heat treatment; with shape, dimensions and tolerances according EN 10219-2; performance characteristics according appendix ZA.1 of the product standart. Function - for steel structures and combined steel and reinforced concrete structures.

Z06 Claims are allowed within 14 days from product receipt. In order to consider a claim, the customer must provide a quality inspection control document and a marking on the claimed goods. Claims associated with unloading and storage of the goods will not be accepted.

Z07 Declaration of performance № 3130019827 HUS CFRHS S235JRH /2021

Declaration of performance № 3130019827 HUS CFCHS S235JRH /2021