

EU - type Examination Certificate

This is to certify that the product listed below conforms to the requirements of the

Pressure Equipment Directive 2014/68/EU

Annex III Module B (production)

Certificate Number

Date of Issue

Manufacturer

HPiVS-iP1002-184-I-01-00

14-Jul-2023

Date of Expiry

13-Jul-2033

Ningbo Hrale Plate Heat Exchanger Co., Ltd

No.98, Binwan Road, Binhai New Area, Fenghua, Ningbo City,

China, 315506

Description of Pressure

Equipment

Plate heat exchanger models:

B3-30, B3-40, B3-42, B3-52, B3-60, B3-63, B3-68, B3-

80, B3-95, B3-105, B3-115

Drawing No

T30V-011 Rev.01; T40RD-016 Rev.01; T40RD-017 Rev.01; T42V-002 Rev.0. T52DW-052 Rev.01; T60A-001 Rev.01; T63A-005 Rev.01; T68A-012 Rev.01.

T95A-075 Rev.01; T105A-090 Rev.01.; T68A-066; T80-002; T115A-458.

Representative Specimen

Serial No

B3-68-30-4.5; B3-80-30-4.5; B3-115-30-3.0

Design Pressure (bar)

Design Temperature (°C)

Standards Used

-196 to 225 °C BS EN 14276-1:2020

15-25-30-45-50 bar

Report Reference

iP1002-184-DR01

This Certificate is valid in any European Economic Area Member State.

This Certificate has been issued by HPi Verification Services (Ireland) Ltd. which is a body notified to the European Commission according to the provisions of the Pressure Equipment Directive (Notified Body number 2810).

This Certificate is issued following the assessment of a representative sample of the Pressure Equipment detailed above in accordance with the provisions of the above regulations. The equipment must be subject to an appropriate conformity assessment module during manufacture prior to the CE Mark being affixed.

Quality Director

Technical Director

An INAB accredited Certification Body 6022.

EU Notified Body No. 2810 Company registered in Ireland #577786

enquiries@hpivs.ie www.hpivs.ie

+353 (0)1 8017008

HPi Verification Services (Ireland) Ltd. Clonross Dunshaughlin, Co.Meath A85 XN59, Ireland